

ADDENDUM #1

16 APRIL, 2010

IN THE FUTURE, PRIOR TO REVIEW OF SANITARY SEWER PLANS, THE CENTERLINE MUST BE STAKED AND FLAGGED ON THE GROUND. A SITE VISIT WILL BE REQUIRED PRIOR TO APPROVAL OF THE PLANS.

IT WILL BE UP TO THE DESIGN ENGINEER TO DETERMINE THE LOCATION OF R.O.W.'S AND BE PREPARED TO DEFEND THE LOCATION AS SHOWN ON THEIR PLANS, WHETHER PRESCRIPTIVE OR DEDICATED.

THE CONTRACTOR SHOULD NOTIFY THE MADISON COUNTY ENGINEERING DEPARTMENT WITH A SCHEDULE OF DAYS THAT THEY PLAN TO BE WORKING IN THE COUNTY R.O.W.

NOTES SHOULD BE ON THE PLANS STATING:

THE SEWER LINE WILL NOT BE OCCUPYING DITCHES ALONG MADISON COUNTY R.O.W.'S, EXCEPT TO CROSS A DITCH PERPENDICULAR TO THE PROPOSED SANITARY SEWER.

A MINIMUM OF 4' OF COVER IS REQUIRED OVER THE PROPOSED SANITARY SEWER LINE, AND 6' WHERE SANITARY SEWER LINE CROSSES DRAINAGE WAYS.